



Kiwa UK Regulation 4 (KUKreg4) Approval (ATS3)

Certificate number 2009701

Date issued 1st September 2020

Date expired 31st August 2025 Original/Amendment *Original*

Description: BM range of BA type verifiable reduced pressure zone valves with brass bodies. A quarter turn spherical valve is located in each zone to act as a test port. Maximum working pressure 10.0 bar. Maximum operating temperature 60°C.

UK Approval

Issued by Kiwa Watertec

Product Designation: BA BM 015
BA BM 020
BA BM 025
BA BM 032
BA BM 040
BA BM 050

This is to certify that the above range of products manufactured/supplied by

Company name: Watts Industries UK Ltd.

Has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations, Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRNs) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRNs for this certificate: R001, R120, R415, R425

David Jay, Business Unit Manager – Authorised Signatory

Kiwa Watertec

Certificate issued to:
Watts Industries UK Ltd
Colmworth Business Park
Eaton Socon
Cambridgeshire
PE19 8YX

CERTIFICATE

3901770301

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
F +44 (0)495 304496
uk.water@kiwa.com
www.kiwa.co.uk

