



Attestation of Conformity

No. N8A 077740 0026 Rev. 00

Holder of Certificate: Watts Industries Italia S.r.l.

Via Vienna 3 38121 Trento TN

ITALY

Product: Pressure switches

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105203088601

Date, 2021-06-08

(Martin Ma)

Workin Mer

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.







Attestation of Conformity

No. N8A 077740 0026 Rev. 00

Model(s): FLU25PL

Parameters:

Rated Voltage/ Frequency:	230V~, 50/60Hz
Rated Current:	1E4 for 10A, 5E4 for 5A
Kind of load:	Substantially resistive load
Purpose of control:	Pressure operating control
Construction:	Incorporated control
IP-Protection Degree:	IP64
Action Type:	1.B
Number of cycles of automatic action:	1E4 for 10A, 5E4 for 5A
Operating value(s):	From 0 to 1.0MPa
Max. Working pressure:	1.0MPa
Pressure medium:	Water
Temperature limit of Switching Head (Tmax):	T60
Temperature limit of mounting surfaces (Ts):	T60
Temperature limit of liquid	T110

Tested according to:

EN 60730-2-6:2016/A1:2020 EN 60730-1:2016/A1:2019



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

