

CERTIFICATE

15632 1707 09A

according to EN 15632-3:2010+A1:2014

for

pre-insulated flexible non-bonded pipe system
with one, two or four plastic service pipes:

MICROFLEX®

by order of

Watts Industries Italia S.r.l.

This certificate is based on reports 1298E5175 dated from 2015-11-05, 1454E5288 dated from 2017-07-12 and 1455E5288 dated from 2017-07-12.

This certificate covers MICROFLEX® pipes those consist of one, two or four service pipes of peroxide cross-linked polyethylene (PE-Xa) with an oxygen diffusion barrier for all heating service pipes, a thermal insulation of polyolefine foam and a casing of high density polyethylene (HDPE).

This certificate excludes meeting of requirements of EN 15632-1:2009+A1:2014 Cl. 5.2 & 5.3 & 5.5 for MICROFLEX® pipes with casings without ≥ 2 % carbon black as UV stabilizer.

MICROFLEX® pipes described above meet requirements given in EN 15632-3:2010+A1:2014.

Hemmingen, 2017-07-12


Thomas Grage
Managing Director

**FFI** FERNWÄRME
FORSCHUNGSINSTITUT
GmbH
Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaerme.de


Sönke Kraft
Project Manager