

SGWA
Swiss Gas and Water
Industry Association
Grütlistrasse 44
CH- 8027 Zürich

Certification body water



Certificate No.: 0810-5442

Applicant: Socla SAS, 365, rue du Lieutenant Putier, FR- 71530 Viréy-Le-Grand

In accordance with our regulation ZW101 „general terms and conditions of the SGWA certification body water“ the SGWA certify the following serial products:

Rubric: Backflow preventer BA and GB

Denomination: SOCLA BA BM
WATTS GmbH BA BM

Types: SOCLA BA:
BM 015, BM 020, BM 025, BM 032, BM 040, BM 050

WATTS GmbH BA:
BM 015, BM 020, BM 025, BM 032, BM 040, BM 050

DN: 15...50 PN: 10 tmax: 65 °C

Certification Standard: SGWA ZW135 (01/19), EN 12729 (2002)

Validity: 31.03.2024


Conditions (C) / Remarks (R):
None

The applicant is entitled to offer the above mentioned products as certificated by the SGWA and to use the above SGWA-conformity mark (publication in the list of certificates water).



accredited according to
SN EN ISO/IEC 17065

Swiss Gas and Water Industry Association
Certification body water


Javier Fernandez
Head

Zurich, 23.04.2019

page 1 / 2

Socla SAS,365, rue du Lieutenant Putier, FR- 71530 Viréy-Le-Grand

Rubric: Backflow preventer BA and GB

Denomination: SOCLA BA BM
WATTS GmbH BA BM

Types	DN	PN	C*	Acoustic group	Losses kWh/24 h / ErP Class	Content	Index	Metrological class
SOCLA BA:								
BM 015, Art. 70000	15	10	65	I			-	
BM 020, Art. 70001	20	10	65	I			-	
BM 025, Art. 70002	25	10	65	I			-	
BM 032, Art. 70003	32	10	65	I			-	
BM 040, Art. 70004	40	10	65				-	
BM 050, Art. 70005	50	10	65				-	
WATTS GmbH BA:								
BM 015, Art. 10002343	15	10	65	I			-	
BM 020, Art. 10002344	20	10	65	I			-	
BM 025, Art. 10002345	25	10	65	I			-	
BM 032, Art. 10002346	32	10	65	I			-	
BM 040, Art. 10002347	40	10	65				-	
BM 050, Art. 10002348	50	10	65				-	

SVGW

Schweizerischer Verein
des Gas- und Wasserfaches
Grütlistrasse 44
CH- 8027 Zürich

Zertifizierungsstelle Wasser



Zertifikat Nr.: 0810-5442

Antragsteller: Socla SAS, 365, rue du Lieutenant Putier, FR- 71530 Viréy-Le-Grand

Gestützt auf das Reglement ZW101 „Allgemeine Geschäftsbedingungen der SVGW Zertifizierungsstelle Wasser“ zertifiziert der SVGW die folgenden Serienprodukte:

Rubrik: Systemtrenngeräte Bauart BA und GB

Bezeichnung: SOCLA BA BM
WATTS GmbH BA BM

Typen: SOCLA BA:
BM 015, BM 020, BM 025, BM 032, BM 040, BM 050

WATTS GmbH BA:
BM 015, BM 020, BM 025, BM 032, BM 040, BM 050

DN: 15...50 PN: 10 tmax: 65 °C

Zertifizierungsgrundlage: SVGW ZW135 (01/19), EN 12729 (2002)

Gültigkeit: 31.03.2024


Auflagen (A) / Bemerkungen (B):
Keine

Der Antragsteller ist berechtigt, die oben erwähnten Produkte als SVGW zertifiziert anzubieten und das obige SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Wasser).



akkreditiert nach
SN EN ISO/IEC 17065

Schweizerischer Verein des Gas- und Wasserfaches
Zertifizierungsstelle Wasser


Javier Fernandez
Leiter

Zürich, 23.04.2019

Seite 1 / 2

Rubrik: Systemtrenngeräte Bauart BA und GB

Bezeichnung: SOCLA BA BM
WATTS GmbH BA BM

Typen	DN	PN	C°	Geräusch- gruppe	Verluste kWh/24 h / ErP Klasse	Inhalt	Index	Metrologische Klasse
SOCLA BA:								
BM 015, Art. 70000	15	10	65	I				
BM 020, Art. 70001	20	10	65	I				
BM 025, Art. 70002	25	10	65	I				
BM 032, Art. 70003	32	10	65	I				
BM 040, Art. 70004	40	10	65					
BM 050, Art. 70005	50	10	65					
WATTS GmbH BA:								
BM 015, Art. 10002343	15	10	65	I				
BM 020, Art. 10002344	20	10	65	I				
BM 025, Art. 10002345	25	10	65	I				
BM 032, Art. 10002346	32	10	65	I				
BM 040, Art. 10002347	40	10	65					
BM 050, Art. 10002348	50	10	65					